



HOUSE

RECIRCULATION PUMP POWER

FLOAT SWITCH

CONTROL PANEL

AIR PRESSURE SWITCH

AIR PUMP POWER

AIR PUMP

AIR PUMP

AERATION RISERS

CLARIFICATION RISERS

GENERAL NOTES:

- 1. WIRE SHOULD BE 12/2 UF DIRECT BURIAL.

PART NUMBER:		REVISION DATE	REVISION
U.S. AND FOREIGN PATENTS PENDING  © MMXXIV	<b>norweco</b>		DRAWN BY CLB
	NORWECO HYDRO-KINETIC 1000 - 1500 GPD SYSTEM WIRING DIAGRAM		APPROVED BY JMM
			DATE 11-4-2024
			SCALE NTS
		DRAWING NO.	PC-2-0333